

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : LAGUNA AAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : SANTA ROSA CITY HEALTH OFFICE I

SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 25

TOTAL PARAMETERS TESTED : 5

ANALYSIS DATE(S) : 03/01/2021 – 03/17/2021

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C)	RESIDUAL CHLORINE ^B (mg/L)	COLIFORM ^C		HPC ^D (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
			MDL: NA LOQ: NA	MDL: 0.06 LOQ: 0.20			
BRGY. BIÑAN							
03/17/2021 10:30	S21-2177	Laguna Wellfield 1	7.40 /27.3	0.01	ABSENCE	ABSENCE	< 1
BRGY. CAINGIN							
03/08/2021 12:54	S21-1817	Water Pump, Block 57, Phase 1, Southville	-	1.11	ABSENCE	ABSENCE	< 1
03/08/2021 13:20	S21-1818	Block 25 Lot 7, Phase 3, Southville	-	0.32	ABSENCE	ABSENCE	< 1
03/08/2021 13:02	S21-1819	Southville Integrated Highschool	-	0.03	ABSENCE	ABSENCE	5
03/08/2021 13:17	S21-1821	Water Pump, Phase 8 & 9, Southville	-	0.22	ABSENCE	ABSENCE	< 1
03/08/2021 13:22	S21-1822	Block 2 Lot 16, Phase 9, Southville	-	0.16	ABSENCE	ABSENCE	< 1
03/08/2021 13:45	S21-1823	Water Pump, Phase 5, Southville	-	0.29	ABSENCE	ABSENCE	< 1
BRGY. KANLURAN							
03/08/2021 12:06	S21-1814	Gate Entrance, Alfonso Homes I	-	0.02	ABSENCE	ABSENCE	< 1
03/08/2021 11:56	S21-1812	#621 Rizal Boulevard	-	0.03	ABSENCE	ABSENCE	< 1
BRGY. MALUSAK							
03/08/2021 11:38	S21-1813	Santa Rosa City Hall	-	0.02	ABSENCE	ABSENCE	33
03/08/2021 11:45	S21-1820	Drinking Fountain 1, Central Elementary School	-	0.02	ABSENCE	ABSENCE	5
BRGY. SINALHAN							
03/08/2021 10:54	S21-1811	Block 8 Lot 16, Bayshore III	-	0.09	ABSENCE	ABSENCE	39

NOT VALID WITHOUT QR CODE



REVIEWED BY:

ALYSSA MARIE C. PENALES, RMT
Microbiology Unit Manager (OIC)
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:

ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C)	RESIDUAL CHLORINE ^B (mg/L)	COLIFORM ^C		HPC ^D (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
			MDL: NA LOQ: NA	MDL: 0.06 LOQ: 0.20			
BRGY. TAGAPO							
03/02/2021 12:18	S21-1647	#60 31 JP Rizal Boulevard	-	0.80	ABSENCE	ABSENCE	< 1
03/02/2021 12:47	S21-1649	Block 1 Lot 18, Fairfield of Margana Subdivision	-	1.06	ABSENCE	ABSENCE	< 1
03/02/2021 12:29	S21-1657	Water Pump, Rosewood Homes I	-	0.99	ABSENCE	ABSENCE	< 1
03/02/2021 12:34	S21-1658	Block 3 Lot 31, Rosewood Homes I	-	1.01	ABSENCE	ABSENCE	< 1
03/02/2021 13:13	S21-1659	Block 2 Lot 18, Rosewood Homes II	-	1.09	ABSENCE	ABSENCE	< 1
03/02/2021 11:04	S21-1648	Eye wash, Buena Rosa 1 Subdivision	-	0.05	ABSENCE	ABSENCE	50
03/02/2021 12:10	S21-1650	Block 1 Lot 64, Buena Rosa 10 Subdivision	-	0.10	ABSENCE	ABSENCE	< 1
03/02/2021 11:25	S21-1651	Cistern Tank, SM Santa Rosa	-	0.11	ABSENCE	ABSENCE	< 1
03/02/2021 11:30	S21-1652	Admin Pantry, SM Santa Rosa	-	0.52	ABSENCE	ABSENCE	260
03/02/2021 13:32	S21-1653	Cistern Tank, Robinson's Mall	-	0.23	ABSENCE	ABSENCE	130
03/02/2021 13:36	S21-1654	Ilonggo, Robinson's Mall	-	0.09	ABSENCE	ABSENCE	< 1
03/01/2021 14:28	S21-1610	Water Pump, Metrogate Heritage Subd.	7.59 / 28.1	0.68	ABSENCE	ABSENCE	< 1
03/01/2021 14:48	S21-1611	Clubhouse, Metrogate Heritage Subd.	7.54 / 27.2	0.40	ABSENCE	ABSENCE	< 1

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: **HPC** – Heterotrophic Plate Count; **CFU** – Colony Forming Units; **MDL** – Method Detection Limit; **LOQ** – Limit of Quantification; **NA** – Not Applicable

DEVIATIONS: No deviation noted on sample collection and submission.


METHODS: **A** – Electrometric; **B** – Colorimetric; **C** – Enzyme Substrate; **D** – Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition


NOT VALID WITHOUT QR CODE



REVIEWED BY:


ALYSSA MARIE C. PENALES, RMT
Microbiology Unit Manager (OIC)
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : LAGUNA AAAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : SANTA ROSA CITY HEALTH OFFICE II

SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 47

TOTAL PARAMETERS TESTED : 5

ANALYSIS DATE(S) : 03/01/2021 – 3/26/2021

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C)	RESIDUAL CHLORINE ^B (mg/L)	COLIFORM ^C		HPC ^D (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
			MDL: NA LOQ: NA	MDL: 0.06 LOQ: 0.20			
BRGY. BIÑAN							
03/17/2021 10:30	S21-2177	Laguna Wellfield 1	7.40 / 27.3	0.01	ABSENCE	ABSENCE	< 1
BRGY. BALIBAGO							
03/02/2021 10:40	S21-1646	#1354 Facundo Compound	-	0.04	ABSENCE	ABSENCE	< 1
03/01/2021 10:27	S21-1580	Clubhouse, South Hampton Residences	7.35 / 30.6	0.24	ABSENCE	ABSENCE	< 1
03/01/2021 14:18	S21-1609	Block 5 Lot 25, JB Village	7.61 / 27.4	0.36	ABSENCE	ABSENCE	< 1
03/24/2021 10:03	S21-2292	Cistern Tank, Waltermart Santa Rosa	7.67 / 28.6	0.14	ABSENCE	ABSENCE	1
03/24/2021 10:16	S21-2293	2 nd Floor faucet, Waltermart, Santa Rosa	7.42 / 28.5	0.08	ABSENCE	ABSENCE	4
BRGY. DILA							
03/01/2021 10:41	S21-1597	Water Pump, Phase 3E, Mabuhay Homes 2000, Golden City Subdivision	7.51 / 27.8	0.29	ABSENCE	ABSENCE	< 1
03/01/2021 10:59	S21-1598	Block 2 Lot 10, Phase 3E, Mabuhay Homes 2000, Golden City Subdivision	7.50 / 28.6	0.19	ABSENCE	ABSENCE	< 1
03/01/2021 11:15	S21-1599	Water Pump, Block 12, Phase 2E, Mabuhay Homes 2000	7.40 / 27.1	0.31	ABSENCE	ABSENCE	< 1
03/01/2021 11:28	S21-1600	Block 13 Lot 5, Phase 2E, Mabuhay Homes 2000	7.45 / 27.6	0.16	ABSENCE	ABSENCE	< 1
03/01/2021 10:48	S21-1590	Clubhouse, Alabaster St., Villa Esmeralda	7.50 / 30.1	0.02	ABSENCE	ABSENCE	< 1
03/01/2021 12:01	S21-1601	Drinking Fountain, Dila Elementary	7.48 / 28.1	0.14	ABSENCE	ABSENCE	< 1
BRGY. DITA							
03/01/2021 12:15	S21-1602	Block 24 Lot 2, New Santa Rosa Homes	7.56 / 28.1	0.36	ABSENCE	ABSENCE	< 1
03/01/2021 12:28	S21-1603	Block 19 Lot 11, New Santa Rosa Homes	7.51 / 27.1	0.28	ABSENCE	ABSENCE	< 1
03/01/2021 12:39	S21-1604	Water Tank, SolCar Ville Subdivision	7.43 / 27.6	0.48	ABSENCE	ABSENCE	< 1

NOT VALID WITHOUT QR CODE



REVIEWED BY:

ALYSSA MARIE C. PENALES, RMT
Microbiology Unit Manager (OIC)
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:

ANNA KARLA S. BUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C)	RESIDUAL CHLORINE ^B (mg/L)	COLIFORM ^C		HPC ^D (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
			MDL: NA LOQ: NA	MDL: 0.06 LOQ: 0.20			
03/01/2021 13:05	S21-1605	Block 3 Lot 7, SolCar Ville Subdivision	7.40 / 27.3	0.31	ABSENCE	ABSENCE	< 1
03/01/2021 13:18	S21-1606	#1780, National Road	7.48 / 28.1	0.28	ABSENCE	ABSENCE	< 1
03/01/2021 15:15	S21-1612	R & B Ice Plant, Inc.	7.50 / 28.1	0.45	ABSENCE	ABSENCE	< 1
03/01/2021 11:17	S21-1581	Clubhouse, San Lorenzo Royale	7.42 / 30.2	0.08	ABSENCE	ABSENCE	< 1
BRGY. DON JOSE							
03/11/2021 14:20	S21-2015	Science High School, Phase 1, Laguna Bel-Air	-	0.28	ABSENCE	ABSENCE	-
03/11/2021 13:13	S21-2017	Church, Block 108, Phase 5, Laguna Bel-Air	-	0.10	ABSENCE	ABSENCE	-
03/11/2021 14:28	S21-2016	Church, Phase 1, Laguna Bel-Air	-	0.20	ABSENCE	ABSENCE	-
03/11/2021 14:09	S21-2021	Block 47 Lot 12, Phase 4, Laguna Bel-Air	-	< 0.02	ABSENCE	ABSENCE	-
03/11/2021 14:40	S21-2008	8001, Pump 1, Acacia St., Santa Rosa Village I	7.65 / 27.8	0.51	ABSENCE	ABSENCE	-
03/11/2021 14:59	S21-2009	Clubhouse, Phase 4B, Santa Rosa Village I	7.68 / 28.9	0.38	ABSENCE	ABSENCE	-
03/11/2021 15:15	S21-2010	Clubhouse, Santa Rosa Village II	7.60 / 28.5	0.31	ABSENCE	ABSENCE	-
03/11/2021 15:29	S21-2011	Pump 9 & 10, Santa Rosa Estates I	7.61 / 28.1	0.59	ABSENCE	ABSENCE	-
03/11/2021 15:42	S21-2012	Clubhouse, Santa Rosa Estates I	7.68 / 27.9	0.40	ABSENCE	ABSENCE	-
03/11/2021 16:29	S21-2014	Drinking Fountain, Don Jose National High School	7.68 / 27.6	0.81	ABSENCE	ABSENCE	-
BRGY. MACABLING							
03/02/2021 13:54	S21-1660	Water Pump, Buena Rosa 9 Subdivision	-	0.48	ABSENCE	ABSENCE	8
03/02/2021 13:58	S21-1661	Block 4 Lot 44, Phase 2, Buena Rosa 9 Subdivision	-	0.31	ABSENCE	ABSENCE	< 1
03/02/2021 14:11	S21-1655	Water Pump, Corinthian Subdivision	-	0.95	ABSENCE	ABSENCE	62
03/02/2021 14:21	S21-1656	Block 11 Lot 19, Corinthian Subdivision	-	0.88	ABSENCE	ABSENCE	< 1
BRGY. MALITLIT							
03/01/2021 13:36	S21-1607	Clubhouse, Casan Residencia Subdivision	7.41 / 27.5	0.17	ABSENCE	ABSENCE	4
03/01/2021 11:48	S21-1582	Water Pump, Block 3 Lot 1, Phase 1A Annex, San Lorenzo Subdivision	7.51 / 29.6	0.22	ABSENCE	ABSENCE	< 1
03/01/2021 12:07	S21-1583	Block 5 Lot 25, Phase 1A Annex, San Lorenzo Subdivision	7.55 / 30.4	0.20	ABSENCE	ABSENCE	< 1
03/01/2021 13:20	S21-1586	Water Pump, Main Road, Phase 2, Terra Fortuna	7.47 / 27.6	0.09	ABSENCE	ABSENCE	2
03/01/2021 14:20	S21-1587	Block 11 Lot 16, Terra Fortuna	7.41 / 29.6	0.07	ABSENCE	ABSENCE	< 1
03/01/2021 12:30	S21-1584	Water Pump, 9999 W, Villa Las Casas	7.46 / 30.3	0.15	ABSENCE	ABSENCE	< 1
03/01/2021 12:59	S21-1585	Block 1 Lot 17, Villa Las Casas	7.55 / 27.3	0.08	ABSENCE	ABSENCE	< 1
03/01/2021 14:03	S21-1608	Drinking Fountain, Malitlit Elementary	7.38 / 28.6	0.13	ABSENCE	ABSENCE	< 1

NOT VALID WITHOUT QR CODE



REVIEWED BY:

ALYSSA MARIE C. PENALES, RMT
Microbiology Unit Manager (OIC)
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:

ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C)	RESIDUAL CHLORINE ^B (mg/L)	COLIFORM ^C		HPC ^D (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
			MDL: NA LOQ: NA	MDL: 0.06 LOQ: 0.20			
BRGY. POOC							
03/08/2021 12:25	S21-1815	Water Pump, Villa Mercedes	-	0.08	ABSENCE	ABSENCE	5
03/08/2021 12:33	S21-1816	Block 2 Lot 1, Villa Mercedes	-	0.11	ABSENCE	ABSENCE	< 1
BRGY. PULONG STA. CRUZ							
03/01/2021 09:30	S21-1579	Lagatao Residence, Buklod Diwa	7.44 / 28.6	0.27	ABSENCE	ABSENCE	< 1
03/01/2021 09:50	S21-1588	Drinking Fountain 1, Pulong Sta. Cruz Elementary School	7.44 / 29.6	0.30	ABSENCE	ABSENCE	< 1
03/01/2021 10:04	S21-1589	Drinking Fountain II, Pulong Sta. Cruz Elementary School	7.41 / 29.1	0.32	ABSENCE	ABSENCE	< 1
BRGY. SANTO DOMINGO							
03/11/2021 15:59	S21-2013	Clubhouse Santa Rosa Estates II	7.56 / 27.5	0.45	ABSENCE	ABSENCE	-

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: **HPC** – Heterotrophic Plate Count; **CFU** – Colony Forming Units; **MDL** – Method Detection Limit; **LOQ** – Limit of Quantification; **NA** – Not Applicable

DEVIATIONS: No deviation noted on sample collection and submission.


METHODS: **A** – Electrometric; **B** – Colorimetric ; **C** - Enzyme Substrate; **D** – Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition


NOT VALID WITHOUT QR CODE



REVIEWED BY:


ALYSSA MARIE A. PENALES, RMT
Microbiology Unit Manager (OIC)
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.