

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna  
CONTACT NO.: (049) 543-1916  
WEBSITE: [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

**CUSTOMER NAME : LAGUNA AAWATER CORPORATION**

**ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna**

**ATTENTION : SANTA ROSA CITY HEALTH OFFICE I**

### SUMMARY OF LABORATORY ANALYSIS

**NO. OF SAMPLES : 25**

**TOTAL PARAMETERS TESTED : 5**

**ANALYSIS DATE(S) : 01/07/2021-01/27/2021**

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature <sup>A</sup> (- / °C)	RESIDUAL CHLORINE <sup>B</sup> (mg/L)	COLIFORM <sup>C</sup>		HPC <sup>D</sup> (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
			MDL: NA LOQ: NA	MDL: 0.06 LOQ: 0.20			
<b>BRGY. BIÑAN</b>							
01/07/2021 14:20	S20-0223	Laguna Wellfield 1	-	0.29	ABSENCE	ABSENCE	1
<b>BRGY. CAINGIN</b>							
01/13/2021 10:23	S21-0404	Water Pump, Block 57, Phase 1, Southville	7.45 / 27.0	0.16	ABSENCE	ABSENCE	< 1
01/13/2021 10:38	S21-0405	Block 25 Lot 7, Phase 3, Southville	7.48 / 28.6	0.10	ABSENCE	ABSENCE	< 1
01/25/2021 10:21	S21-0683	Southville Integrated Highschool	7.60 / 28.6	0.21	ABSENCE	ABSENCE	< 1
01/25/2021 10:10	S21-0682	Water Pump, Phase 8 & 9, Southville	7.51 / 27.8	0.30	ABSENCE	ABSENCE	< 1
01/25/2021 10:28	S21-0684	Santos Residence, Phase 9, Southville	7.60 / 27.9	0.23	ABSENCE	ABSENCE	< 1
<b>BRGY. KANLURAN</b>							
01/13/2021 09:36	S21-0401	Block 18 Lot 2, Alfonso Homes I	7.55 / 28.6	0.23	ABSENCE	ABSENCE	< 1
01/13/2021 09:15	S21-0399	#621 Rizal Boulevard	7.45 / 27.6	0.38	ABSENCE	ABSENCE	1
<b>BRGY. MALUSAK</b>							
01/13/2021 09:27	S21-0400	Santa Rosa City Hall	7.48 / 27.6	0.20	ABSENCE	ABSENCE	< 1
01/13/2021 11:10	S21-0407	Drinking Fountain 1, Central Elementary School	7.50 / 27.6	0.26	ABSENCE	ABSENCE	< 1
<b>BRGY. SINALHAN</b>							
01/13/2021 08:40	S21-0397	Amoranto Compound, Purok II	7.65 / 26.6	0.30	ABSENCE	ABSENCE	< 1
01/13/2021 08:55	S21-0398	Block 8 Lot 16, Bayshore III	7.51 / 26.4	0.28	ABSENCE	ABSENCE	< 1

NOT VALID WITHOUT QR CODE



REVIEWED BY:

ALYSSA MARIE C. PENALES, RMT  
Microbiology Unit Manager (OIC)  
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:

ANNA KARLA S. GUTIERREZ, RMT  
Laboratory Services Manager  
License No(s). (PRC 0060958)

*This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis*

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature <sup>A</sup> ( - / °C)	RESIDUAL CHLORINE <sup>B</sup> (mg/L)	COLIFORM <sup>C</sup>		HPC <sup>D</sup> (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
			MDL: NA LOQ: NA	MDL: 0.06 LOQ: 0.20			
<b>BRGY. TAGAPO</b>							
01/07/2021 11:01	S21-0184	#60 31 JP Rizal Boulevard	-	0.25	ABSENCE	ABSENCE	8
01/07/2021 11:45	S21-0186	Block 1 Lot 18, Fairfield of Margana Subdivision	-	0.35	ABSENCE	ABSENCE	< 1
01/07/2021 11:26	S21-0194	Water Pump, Rosewood Homes I	-	0.48	ABSENCE	ABSENCE	< 1
01/07/2021 11:32	S21-0195	Block 3 Lot 31, Rosewood Homes I	-	0.18	ABSENCE	ABSENCE	< 1
01/07/2021 11:54	S21-0196	Block 4 Lot 1, Rosewood Homes II	-	0.39	ABSENCE	ABSENCE	< 1
01/07/2021 10:41	S21-0185	Pump house faucet, Buena Rosa 1 Subdivision	-	0.26	ABSENCE	ABSENCE	< 1
01/07/2021 11:02	S21-0187	Block 1 Lot 64, Buena Rosa 10 Subdivision	-	0.30	ABSENCE	ABSENCE	< 1
01/07/2021 12:39	S21-0188	Cistern Tank, SM Santa Rosa	-	0.16	ABSENCE	ABSENCE	< 1
01/07/2021 12:45	S21-0189	Admin Pantry, SM Santa Rosa	-	0.61	ABSENCE	ABSENCE	< 1
01/07/2021 12:12	S21-0190	Cistern Tank, Robinson's Mall	-	0.03	ABSENCE	ABSENCE	16
01/12/2021 12:32	S21-0305	Ilonggo, Robinson's Mall	-	0.13	ABSENCE	ABSENCE	64
01/07/2021 12:30	S21-0178	Water Pump, Metrogate Heritage Subd.	7.61 / 29.1	0.69	ABSENCE	ABSENCE	< 1
01/07/2021 12:40	S21-0179	Clubhouse, Metrogate Heritage Subd.	7.68 / 27.6	0.54	ABSENCE	ABSENCE	< 1

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: HPC – Heterotrophic Plate Count; CFU – Colony Forming Units; MDL – Method Detection Limit; LOQ – Limit of Quantification; NA – Not Applicable

DEVIATIONS: No deviation noted on sample collection and submission.

METHODS: A – Electrometric; B – Colorimetric; C – Enzyme Substrate; D – Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition

NOT VALID WITHOUT QR CODE



REVIEWED BY:

ALYSSA MARIE C. PENALES, RMT  
Microbiology Unit Manager (OIC)  
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:

ANNA KARLA S. GUTIERREZ, RMT  
Laboratory Services Manager  
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna  
**CONTACT NO.:** (049) 543-1916  
**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

**CUSTOMER NAME :** LAGUNA AAAWATER CORPORATION

**ADDRESS :** G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

**ATTENTION :** SANTA ROSA CITY HEALTH OFFICE II

### SUMMARY OF LABORATORY ANALYSIS

**NO. OF SAMPLES :** 48

**TOTAL PARAMETERS TESTED :** 5

**ANALYSIS DATE(S) :** 01/07/2021-1/27/2021

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature <sup>A</sup> (- / °C)	RESIDUAL CHLORINE <sup>B</sup> (mg/L)	COLIFORM <sup>C</sup>		HPC <sup>D</sup> (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
<b>BRGY. BIÑAN</b>							
01/07/2021 14:20	S20-0223	Laguna Wellfield 1	-	0.29	ABSENCE	ABSENCE	1
<b>BRGY. BALIBAGO</b>							
01/07/2021 14:23	S21-0183	#1354 Facundo Compound	-	0.26	ABSENCE	ABSENCE	< 1
01/07/2021 09:39	S21-0153	5555 Water Pump Elevated, South Hampton Residences	7.57 / 29.4	0.10	ABSENCE	ABSENCE	< 1
01/07/2021 09:44	S21-0154	Clubhouse, South Hampton Residences	7.42 / 30.5	0.37	ABSENCE	ABSENCE	< 1
01/07/2021 11:55	S21-0177	Block 5 Lot 25, JB Village	7.50 / 28.6	0.26	ABSENCE	ABSENCE	< 1
01/25/2021 09:27	S21-0680	Cistern Tank, Waltermart Santa Rosa	7.48 / 29.3	0.12	ABSENCE	ABSENCE	< 1
01/25/2021 09:01	S21-0681	2 <sup>nd</sup> Floor, Waltermart, Santa Rosa	7.45 / 29.4	0.08	ABSENCE	ABSENCE	< 1
<b>BRGY. DILA</b>							
01/07/2021 09:20	S21-0166	Water Pump, Phase 3E, Mabuhay Homes 2000	7.48 / 27.7	0.19	ABSENCE	ABSENCE	< 1
01/07/2021 09:29	S21-0167	Block 2 Lot 10, Mabuhay Homes 2000	7.45 / 27.6	0.14	ABSENCE	ABSENCE	< 1
01/07/2021 09:38	S21-0168	Water Pump, Block 12, Phase 2E, Mabuhay Homes 2000	7.58 / 27.5	0.36	ABSENCE	ABSENCE	< 1
01/07/2021 09:55	S21-0169	Block 13 Lot 5, Phase 2E, Mabuhay Homes 2000	7.48 / 28.6	0.28	ABSENCE	ABSENCE	< 1
01/07/2021 10:59	S21-0165	Block 29 Lot 16, Alabaster St., Villa Esmeralda	7.51 / 28.3	0.22	ABSENCE	ABSENCE	< 1
<b>BRGY. DITA</b>							
01/07/2021 10:22	S21-0170	Block 24 Lot 2, New Santa Rosa Homes	7.54 / 29.8	0.30	ABSENCE	ABSENCE	< 1
01/07/2021 10:38	S21-0171	Block 19 Lot 11, New Santa Rosa Homes	7.55 / 28.5	0.18	ABSENCE	ABSENCE	< 1
01/07/2021 11:10	S21-0172	Water Tank, SolCar Ville Subdivision	7.60 / 29.8	0.48	ABSENCE	ABSENCE	< 1
01/07/2021 11:18	S21-0173	Block 3 Lot 7, SolCar Ville Subdivision	7.59 / 28.5	0.34	ABSENCE	ABSENCE	< 1

**NOT VALID WITHOUT QR CODE**



**REVIEWED BY:**

ALYSSA MARIE C. PENALES, RMT  
Microbiology Unit Manager (OIC)  
License No(s). (PRC 0064969)

**CERTIFIED CORRECT BY:**

ANNA KARLA S. GUTIERREZ, RMT  
Laboratory Services Manager  
License No(s). (PRC 0050968)

*This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.*



ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna  
CONTACT NO.: (049) 543-1916  
WEBSITE: [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature <sup>A</sup> (- / °C)	RESIDUAL CHLORINE <sup>B</sup> (mg/L)	COLIFORM <sup>C</sup>		HPC <sup>D</sup> (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
01/07/2021 11:28	S21-0174	#1780, National Road	7.48 / 27.6	0.14	ABSENCE	ABSENCE	< 1
01/07/2021 13:28	S21-0180	R & B Ice Plant, Inc.	7.65 / 28.1	0.65	ABSENCE	ABSENCE	< 1
01/07/2021 10:12	S21-0155	Water Pump, San Lorenzo Royale	7.37 / 29.6	0.15	ABSENCE	ABSENCE	< 1
01/07/2021 10:33	S21-0156	Block 11 Lot 52, San Lorenzo Royale	7.42 / 28.6	0.12	ABSENCE	ABSENCE	< 1
<b>BRGY. DON JOSE</b>							
01/12/2021 12:29	S21-0312	Science High School, Phase 1, Laguna Bel-Air	7.40 / 28.6	0.27	ABSENCE	ABSENCE	< 1
01/12/2021 12:07	S21-0314	Church, Block 108, Phase 5, Laguna Bel-Air	7.39 / 29.6	0.04	ABSENCE	ABSENCE	< 1
01/12/2021 12:45	S21-0313	Block 34 Lot 59, Phase 1, Laguna Bel-Air	7.37 / 28.6	0.15	ABSENCE	ABSENCE	< 1
01/12/2021 14:17	S21-0318	Block 47 Lot 12, Phase 4, Laguna Bel-Air	7.40 / 29.6	0.15	ABSENCE	ABSENCE	< 1
01/12/2021 10:07	S21-0306	8001, Pump 1, Acacia St., Santa Rosa Village I	7.47 / 27.6	0.35	ABSENCE	ABSENCE	< 1
01/12/2021 10:16	S21-0307	Clubhouse, Phase 4B, Santa Rosa Village I	7.55 / 27.9	0.27	ABSENCE	ABSENCE	< 1
01/12/2021 10:39	S21-0308	Clubhouse, Santa Rosa Village II	7.55 / 28.1	0.49	ABSENCE	ABSENCE	< 1
01/12/2021 10:58	S21-0309	Pump 9 & 10, Santa Rosa Estates I	7.47 / 27.5	0.33	ABSENCE	ABSENCE	< 1
01/12/2021 11:13	S21-0310	Clubhouse, Santa Rosa Estates I	7.62 / 28.3	0.30	ABSENCE	ABSENCE	< 1
01/12/2021 14:33	S21-0319	Drinking Fountain, Don Jose National High School	7.55 / 27.4	0.07	ABSENCE	ABSENCE	< 1
<b>BRGY. MACABLING</b>							
01/07/2021 13:58	S21-0197	Water Pump, Buena Rosa 9 Subdivision	-	0.08	ABSENCE	ABSENCE	11
01/11/2021 07:58	S21-0273	Block 4 Lot 44, Phase 2, Buena Rosa 9 Subdivision	-	0.37	ABSENCE	ABSENCE	< 1
01/07/2021 13:38	S21-0192	Water Pump, Corinthian Subdivision	-	0.51	ABSENCE	ABSENCE	33
01/07/2021 13:45	S21-0193	Block 11 Lot 19, Corinthian Subdivision	-	0.65	ABSENCE	ABSENCE	< 1
<b>BRGY. MALITLIT</b>							
01/07/2021 11:39	S21-0175	Clubhouse, Casan Residencia Subdivision	7.51 / 27.6	0.18	ABSENCE	ABSENCE	< 1
01/07/2021 12:37	S21-0157	Water Pump, Block 3 Lot 1, Phase 1A Annex, San Lorenzo Subd.	7.37 / 29.7	0.35	ABSENCE	ABSENCE	< 1
01/07/2021 13:09	S21-0158	Block 5 Lot 25, Phase 1A Annex, San Lorenzo Subd.	7.44 / 30.1	0.32	ABSENCE	ABSENCE	< 1
01/07/2021 11:17	S21-0161	Water Pump, Main Road, Phase 2, Terra Fortuna	7.40 / 29.6	0.08	ABSENCE	ABSENCE	< 1
01/07/2021 11:40	S21-0162	Block 11 Lot 16, Terra Fortuna	7.43 / 29.7	0.05	ABSENCE	ABSENCE	< 1
01/07/2021 12:01	S21-0159	Water Pump, 9999 W, Villa Las Casas	7.43 / 30.4	0.30	ABSENCE	ABSENCE	< 1
01/07/2021 12:12	S21-0160	Block 1 Lot 17, Villa Las Casas	7.52 / 30.7	0.25	ABSENCE	ABSENCE	< 1

NOT VALID WITHOUT QR CODE



REVIEWED BY:

ALYSSA MARIE C. PENALES, RMT  
Microbiology Unit Manager (OIC)  
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:

ANNA KARLA S. BUTIERREZ, RMT  
Laboratory Services Manager  
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature <sup>A</sup> (- / °C)	RESIDUAL CHLORINE <sup>B</sup> (mg/L)	COLIFORM <sup>C</sup>		HPC <sup>D</sup> (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
<b>BRGY. POOC</b>							
01/13/2021 09:50	S21-0402	Water Pump, Villa Mercedes	7.56 / 25.5	0.14	ABSENCE	ABSENCE	< 1
01/13/2021 10:12	S21-0403	Block 2 Lot 1, Villa Mercedes	7.40 / 26.6	0.10	ABSENCE	ABSENCE	< 1
01/13/2021 10:55	S21-0406	Block 46 Lot 2, Southville II	7.43 / 27.8	0.12	ABSENCE	ABSENCE	< 1
<b>BRGY. PULONG STA. CRUZ</b>							
01/07/2021 08:12	S21-0152	Block 6 Lot 8, Buklod Diwa	7.47 / 29.6	0.23	ABSENCE	ABSENCE	< 1
01/07/2021 08:30	S21-0163	Drinking Fountain 1, Pulong Sta. Cruz Elementary School	7.52 / 28.9	0.42	ABSENCE	ABSENCE	< 1
01/07/2021 08:49	S21-0164	Drinking Fountain II, Pulong Sta. Cruz Elementary School	7.54 / 28.7	0.40	ABSENCE	ABSENCE	< 1
<b>BRGY. SANTO DOMINGO</b>							
01/12/2021 11:44	S21-0311	Clubhouse Santa Rosa Estates II	7.71 / 27.4	0.25	ABSENCE	ABSENCE	< 1

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: HPC – Heterotrophic Plate Count; CFU – Colony Forming Units; MDL – Method Detection Limit; LOQ – Limit of Quantification; NA – Not Applicable

DEVIATIONS: No deviation noted on sample collection and submission.

METHODS: A – Electrometric; B – Colorimetric; C – Enzyme Substrate; D – Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition

NOT VALID WITHOUT QR CODE



REVIEWED BY:

ALYSSA MARIE C. PENALES, RMT  
Microbiology Unit Manager (OIC)  
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:

ANNA KARLA S. GUTERREZ, RMT  
Laboratory Services Manager  
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.